



Summary of Pending Revisions to:  
GIB Standard Design Criteria document  
Dated September 2008

As of 20 October 2010

No.	Ref. Page / Para.	REVISION COMMENTS	Submitter	Disposition
<b>Criteria narrative</b>				
1.	2-4.6	Correct Square Footage for Classroom 21 from 1,400 SF to 1,500 SF	TRADOC (Dobie Phonecon,9/ 28/10)	Accept
2.	Various locations	Correct all DOIM references to NEC (Network Enterprise Center)  Reflect October 2009 change from DOIM to NEC	USISEC- FDED (Nick Saunders)	Accept
3.	2-1.2	Delete reference to TI 800-01 for SF computation methodologies. Replace with "...shall follow current guidance...". Latest methodology is slightly different than TI in two respects. It qualifies the reduction of overhangs to GSF for overhangs less than 3 feet only, while the TI does not make such qualification. Another difference in latest guidance is .5 scope for UEPH interior corridors. Format changes.	USACE (Marion Harrison)	Accept
4.	3-5.6.21 Finish Schedule, pg51	Revise Arms Vault scheduled ceiling material from "Susp Acoustical" to "Concrete".  Typo	USACE (Aric Naeger)	Accept
5.	2-6.1 Small Arms Training Room,pg24	Add the following sentence: "Compressed air stations are required for cleaning the weapons; the minimum number of compressed air stations shall be such that each compressed air station serves a maximum of two occupants at full occupancy." Reason is that Compressed air is required to clean weapons.	USACE (Ben Alexander)	Pending
6.	2-7.6 Mechanical Room	Add the following sentence: "Exhaust the space at a rate which will prevent the space air temperature from rising more than five degrees above the outdoor design temperature for cooling." This not consistent with UFC 4-410-01FA (limits variance to 10 deg) nor with MT RFP.	USACE (Ben Alexander)	Reject-
7.	2-7.2 Student Break and Vending	replace "Heat load calculations shall consider the machines to be installed." with ""heat load of the vending machines shall be included in cooling load calculations."  Same idea, just less ambiguous wording.	USACE (Ben Alexander)	Accept



Summary of Pending Revisions to:  
GIB Standard Design Criteria document  
Dated September 2008

As of 20 October 2010

No.	Ref. Page / Para.	REVISION COMMENTS	Submitter	Disposition
8.	Various Locations	Change all references to the I3A guide to correctly reference the I3A Criteria (latest edition February 2010)  Guidance has become mandatory requirement as of February 2010	USISEC-FDED (Nick Saunders)	Accept
9.	2-5.6 and Finish Schedule	Schedule calls for painted walls for conference rooms. However, paragraph 2-5.6 states that walls shall have acoustical wall panels	USACE-SAS	Pending resolution
10.	3-5.5.4 Signage, 1-3 Design Guidance	Replace IDG with "Installation Requirements"  Avoid IDG controversy while maintaining compliance with installation requirements.	NAO CoS	Accept
11.	1-4 Regulatory Standards	Remove references to UFC and UFGS.  Per recent email guidance from HQ Scott Wick – appears that UFC 1-200-01 still applicable. Will provide language to notify reader to ensure the current requirements.	NAO CoS	Accept/ Reject
12.	1-7 Accessibility Requirements	this para outdated. replace with: "DoD has adopted the Architectural Barriers Act and Americans with Disabilities Act Accessibility Guidelines (as amended August 5, 2005). per DoD memo 31 October, 2008, all facilities will comply with chapters 1 and 2, and 3 through 10 as the mandatory DoD Accessibility "Standard". Carry this change throughout the criteria document	NAO CoS	Accept
13.	1-6.2 Installation Design Guide	Remove IDG, replace with Installation requirements. Require compliance with Installation specific requirements " ..to the extent permitted by prevailing requirements for the adaptation of the standard design to the site. Mandatory features of this standard design criteria shall govern in cases of conflict with the installation specific requirements contained in design guidance and criteria."  Justified to maintain compliance with the GIB Criteria.	NAO CoS	Accept



Summary of Pending Revisions to:  
GIB Standard Design Criteria document  
Dated September 2008

As of 20 October 2010

No.	Ref. Page / Para.	REVISION COMMENTS	Submitter	Disposition
14.	Various locations	Scrub the inapplicable and non-MT  Unclear which UFCs are no longer applicable.	NAO CoS	Pending resolution
15.	Appendix	Update Appendix references with the latest versions.	NAO CoS	Accept
16.		Update the Cost Criteria, ie validate the 15% of construction cost	NAO CoS	Pending resolution
17.	2-2 Coordination	Revise this paragraph to explain the coordination requirements with TRADOC with respect to equipment, etc. IAW conference on 30 August 2010. Explain the protocol, roles and responsibilities between CoS, proponent, User, TRADOC, etc.		Pending resolution
18.	1-4.3 Historic	rephrase this paragraph to say " National Historic Preservation Act". Section 106 of the National Preservation Act of 1966 (NHPA) requires Federal agencies to take into account the effects of their undertakings on historic properties, and afford the Advisory Council on Historic Preservation a reasonable opportunity to comment. this process is facilitated by the Installation Cultural Resource Manager (CRM) in accordance with AR 200-1 Environmental Protection and Enhancement. Prior to a renovation project, consult with the CRM to confirm that applicable NHPA requirements have been met."  This is an update of the requirement	NAO CoS	Accept
19.	1-7.3	Verify that the listed areas are exempt from requiring accessibility – these are not all listed in the ABAAS for DoD facilities.	NAO CoS	Pending resolution



US Army Corps  
of Engineers®

Summary of Pending Revisions to:  
GIB Standard Design Criteria document  
Dated September 2008

As of 20 October 2010

No.	Ref. Page / Para.	REVISION COMMENTS	Submitter	Disposition
20.		Replace reference to IMA to IMCOM	NAO	Accept
<b>Programming Worksheet</b>				
21.	App C	Correct category code for "NCO Training Space" from 17136 to 17120 (to match narrative)		USACE- Banner
22.	App C	Correct Square Footage for Classroom 21 from 1,400 SF to 1,500 SF	TRADOC (Dobie Phonecon,9/ 28/10)	Accept
23.				